

Questions

1. What is the flow of current when a lamp containing a 60-watt bulb is plugged into a standard U.S. outlet?
- a. 6600 volts
 - b. 5.5 volts
 - c. 0.66 amps
 - d. 0.55 amps
 - e. 6600 amps

Solution: Use the equation $P = IV$ where P is given as 60 watts, V is given as 110 volts. Solving for I , which will be in amps:

$$P = IV$$

$$60 \text{ W} = I(110 \text{ V})$$

$$\frac{60}{110} = 0.54545454... \approx 0.55 \text{ A}$$

2. Theoretically, how many lamps like that in question 1 could be on the same circuit before tripping the 15-amp circuit breaker?
- a. 5 lamps
 - b. 15 lamps
 - c. 20 lamps
 - d. 27 lamps
 - e. 55 lamps

Solution: The 60 W bulb uses 0.55 A. The total number of lamps must use under 15 A.

$$\frac{15 \text{ A}}{0.55 \text{ A}} \approx 27; \text{ Check: } 27 \times 0.55 = 14.85$$

Using 28 lamps on the circuit will trip the breaker.

3. How much power is generated by the number of lamps calculated in question 2?
- a. 0.165 watts or less
 - b. 1400 watts or more
 - c. 1650 watts or less
 - d. 0.14 watts or less
 - e. 1650 watts or more

Solution: Use the equation $P = IV$ where I is given as the total current from question 2 in amperes, the potential difference is given as 110 volts. Solving for P , in watts gives:

$$P = IV$$

$$P = (14.85 \text{ A})(110 \text{ V})$$

$$P = 1633.5 \text{ W}$$

4. A hair dryer draws a current of 10 A on its "Hot" setting and a current of 4 A on its "Cool" setting. What percent decrease in power occurs when you switch the hair dryer from the "Hot" setting to the "Cool" setting?

- a. 60% *
- b. 150%
- c. 0.6%
- d. 15%
- e. -150%

Solution: Use the equation $P = IV$ to find the power drawn by the hair dryer on "Hot."

$$P = IV$$

$$P = (10 \text{ A})(110 \text{ V}) = 1100 \text{ W}$$

Next, use the equation again to find the power drawn by the hair dryer on "Cool."

$$P = IV$$

$$P = (4 \text{ A})(110 \text{ V}) = 440 \text{ W}$$

Finally, compute the percent decrease in power using the formula provided:

$$\begin{aligned} \text{Percent decrease} &= \frac{\text{original value} - \text{new value}}{\text{original value}} \times 100 \\ &= \frac{1100 - 440}{1100} \times 100 \\ &= 60\% \end{aligned}$$


Therefore, there is a 60% decrease in power.

5. Referring to the graph of a transient fault, about how much power was the electrical line carrying before the fault occurred?

- a. 200 V
- b. 228 V
- c. 0 V
- d. 50 V
- e. 250 V

Solution: Looking at the graph line, it starts above the halfway point between 200 volts and 250 volts. The closest answer choice is 228 volts for $time = 0$ until the transient fault occurred.

6. Which of the following piecewise functions best describes the graph of the blackout event shown below?



$$\text{a. } f(t) = \begin{cases} 170 & \text{if } 0 \leq t < 4 \\ -85t + 510 & \text{if } 4 \leq t < 6 \\ 0 & \text{if } t \geq 6 \end{cases}$$

$$\text{b. } f(t) = \begin{cases} 170 & \text{if } t < 4 \\ 85t - 510 & \text{if } 4 \leq t < 6 \\ 0 & \text{if } t \geq 6 \end{cases}$$


$$\text{c. } f(t) = \begin{cases} 170 & \text{if } 0 \leq t \leq 4 \\ -85t + 510 & \text{if } 4 \leq t \leq 6 \\ 0 & \text{if } t \geq 6 \end{cases}$$

$$\text{d. } f(t) = \begin{cases} 170 & \text{if } t \leq 4 \\ 85t - 510 & \text{if } 4 < t \leq 6 \\ 0 & \text{if } t > 6 \end{cases}$$


Solution: The leftmost piece of the graph is the horizontal line at $V = 170$, the middle segment of the graph is the line $V = -85t + 510$, which is found by using endpoints $(4, 170)$ and $(6, 0)$ and the rightmost segment of the graph is the horizontal line at $V = 0$.

7. Which of the following graphs shows what a typical brownout would look like in terms of power supply over time?


a.



b.



c.



d. Correct answer:



8. Based on the information provided, why would a silver ground wire be chosen over a copper one?

- Silver conducts an electric charge better than copper.
- Silver has a higher density than copper.
- Silver has a higher Resistivity-density product than copper.
- Silver is more resistive than copper.

Solution:

$$\rho_{\text{COPPER}} = \frac{\text{resistivity-density product}}{\text{density}} = \frac{150}{8.96} = 16.74 \text{ n}\Omega \text{ im}$$

$$\sigma_{\text{COPPER}} = \frac{1}{\rho} = \frac{1}{16.74} = 0.0597 \text{ S/m}$$

$$\rho_{\text{SILVER}} = \frac{166}{10.49} = 15.82 \text{ n}\Omega \text{ im}$$

$$\sigma_{\text{SILVER}} = \frac{1}{15.82} = 0.0632 \text{ S/m}$$

$$\sigma_{\text{SILVER}} > \sigma_{\text{COPPER}}$$

9. What resistance would be required in the circuit, or network, shown?

- a. 960 ohms
- b. 12 ohms
- c. 15 ohms
- d. 0.07 ohms
- e. 8 ohms

Solution: To find resistance, first solve the Ohm's Law equation, $I = \frac{V}{R}$, for resistance (R).

$$I = \frac{V}{R}$$

$$I \times R = \frac{V}{R} \times R$$

$$\frac{I \times R}{I} = \frac{V}{I}$$

$$R = \frac{V}{I}$$

Next, substitute the known values for voltage and current into the new rearranged equation.

$$R = \frac{120 \text{ V}}{8 \text{ A}}$$

$$R = 15 \text{ ohms, or } 15 \Omega$$

Therefore, the resistance in the circuit is 15 ohms.

10. Using the information in the Table, which logic gate should be used when designing a properly functioning relay circuit?

- a. AND
- b. NAND
- c. OR
- d. NOR
- e. EX-NOR